



WEEKLY CONSTRUCTION UPDATE

Project Title: Whitman 20-Inch For CWSRF - 6885	ce Main Replacement	Report #: EP – 08-19-2022
Project Location: Brockton, MA and Whitman, MA	From : 8/15/2022	Week: 18
Client: Whitman, MA	To: 8/19/2022	Engineer Project #: 279-1901
On-Site Engineer: Bob Fitzgerald, Environmental Partners	Contact: (508) 776-7556	
Contractor: C. Naughton Corp.		

CONSTRUCTION ACTIVITIES COMPLETED THIS WEEK:

- 1. C. Naughton had one crew continuing the sewer force main installation on Auburn Street. C. Naughton installed approximately 600 LF of new 20-inch PVC sewer force main along Auburn Street. Approximately 80% of the sewer force main is complete on Auburn Street.
- 2. C. Naughton had a second crew continuing the installation of the water main on Auburn Street. C. Naughton installed approximately 900 LF of the new 12-inch DI water main and two 6-inch water main gate valves on Auburn Street. Approximately 40% of the water main is complete on Auburn Street.
- 3. C. Naughton completed several test pits along Auburn Street via vacuum excavation to verify the location of existing utilities.
- 4. C. Naughton detoured traffic onto Beaver Street and Alger Street while the sewer main work was on-going this week. A copy of the detour plan is attached for reference.
- 5. All trenches will be backfilled, compacted, and paved prior to leaving for the weekend.

WEEK LOOK-AHEAD SCHEDULE:

- 1. C. Naughton will have two crews on site next week (week of 8/22/2022) to continue installation of both the 20-inch PVC sewer force main and 12-inch DI water main on Auburn Street.
- 2. C. Naughton will have a third crew on-site on Monday 8/22 to begin installation of the new 20-inch HDPE sewer force main within the cross-country easement. Work is anticipated to begin in the cross-country easement between Auburn Street in Whitman and Alger Street in Brockton.

- 3. C. Naughton is maintaining a detour of Auburn Street while water and sewer work is on-going. C. Naughton will maintain access for local residents and for emergency vehicles while the detour is on-going.
- 4. Daily traffic updates to the Town's project website will be posted to alert residents of anticipated road closures and detours.

PROJECT PHOTOS



Photo 1: Installation of 12-inch DI Water Main on Auburn Street



Photo 2: Temporary Paving of the Sewer Trench on Auburn Street



Photo 3: Installation of a 6-inch Water Main Gate Valve on Auburn Street

Prepared By: Amanda Shanahan, Project Engineer, Environmental Partners Group, LLC **Reviewed By**: Andrew Grota, Project Manager, Environmental Partners Group, LLC

